

horizontal centres, 1.8m vertical centres

## WINDOWS:

Windows to be uPVC External Grey / Internal White Optiwhite argon gas filled double glazed with 'KS' inner pane coating with warm air edge spacer (1.40 W/m²K U-value). Opening parts shown. Glass in doors and any adjacent windows to be toughened on inside pane; laminated on outer, designed to resist human impact as set in BS6262 Part 4: 2005. Trickle vents to be fitted to opening sashes as shown to achieve 12000mm² rate of ventilation. 25mm Kingspan insulation to be fitted at window jamb, head and cills to prevent thermal bridging

## **RAINWATER GOODS:**

Any discrepancies or queries regarding any part of of the works to be discussed prior to any affected work being carried out.

Drawings not to be scaled and all sizes to be checked on site.

Lighting / Electrical Items all as per Specification and to final positions to be agreed on site by customer.

ANY Sub floor ventilator covered by works to be re-routed to external air.

DRAWINGS TO BE READ AND UNDERSTOOD PRIOR TO WORK COMMENCING, FIGURED DIMENSIONS TO TAKE PREFERENCE OVER SCALED DIMENSIONS, ALL DIMENSIONS AND LEVELS TO BE CHECKED ON SITE. EXISTING DRAINAGE AND SERVICES POSITIONS TO BE CONFIRMED ON SITE.ANY DISCREPANCIES TO BE REPORTED BACK TO ARCHITECT.

CUSTOMER APPROVAL		
SALES ADVISER		
SALES MANAGER		
APPROVAL	DATE	SIGNATURE

PROPOSED EXTENSION

THISTLE CONTRACT NO:

THISTLE HOUSE, WOODSIDE ROAD BRIDGE OF DON, ABERDEEN, AB23 8EF

TEL: 01224 706555 WWW.THISTLE.GROUP DATE APR '24 205 DRAWING NO: SCALE

0 3 5