## Communal Heating Notes

6432-M-FG-M-700-56-704

For Notes, Details refer to the following drawings:

6432-M-Z-M-000-50-900 6432-M-Z-M-000-50-901

For Communal Heating Schematics refer to the following drawings: 6432-M-A-M-700-56-700 6432-M-A-M-700-56-701 6432-M-BC-M-700-56-702 6432-M-DE-M-700-56-703

For Communal Heating Equipment Schedules refer to the following: 6432-M-A-ZZ-600-07-130

For Communal Heating Plantroom & Roof Layout refer to drg: 6432-M-A-01-100-56-100

6432-M-A-16-100-56-100 District Heating Flow

District Heating Return

= M&E Cupboard Area, Refer to 50 Series for HIU position.

This drawing shall be read in conjunction with all other drawings and specifications

32Ø Conduit for TV 10mm QuelStop HPE Graphite Sealant (QHPE310) 32Ø Conduit for Access Control 10mm − 32Ø Conduit for BT 10mm QuelStop QuelStop HPE Graphite Sealant (QHPE310) HPE Graphite Sealant (QHPE310) 40∅ Conduit for Submain 10mm QuelStop HPE Graphite Sealant (QHPE310) BCW Pipework c/w 20mm Insulation & 4mm Quelcoil Continuous Intuwrap (QUELCOIL) District Heating pipework F&R Sprinkler piperwork c/w 670 c/w 40mm Insulation & 4mm 10mm QuelStop HPE Quelcoil Continuous Intuwrap Graphite Sealant (QHPE310) (QUELCOIL) QuelStop Fire Batt (QB50D) Letter Box Detail A


32Ø Conduit for TV 10mm QuelStop HPE Graphite Sealant (QHPE310) 32Ø Conduit for BT 10mm 32Ø Conduit for Access Control 10mm QuelStop QuelStop HPE Graphite Sealant (QHPE310) HPE Graphite Sealant (QHPE310) 40∅ Conduit for Submain 10mm QuelStop HPE Graphite Sealant (QHPE310) BCW Pipework c/w 20mm Insulation & 4mm Quelcoil Continuous Intuwrap (QUELCOIL) Sprinkler piperwork c/w District Heating pipework F&R 670 10mm QuelStop HPE c/w 40mm Insulation & 4mm Graphite Sealant (QHPE310) Quelcoil Continuous Intuwrap (QUELCOIL) QuelStop Fire Batt (QB50D) Letter Box Detail B


Sheet Notes:


This drawing is the property of Designbrook Ltd and as such may not be copied or communicated to a third party without written authorisation.

This drawing conveys design intent and is provided to assist the contractor in the development of their working drawings. THE CONTRACTOR SHALL NOT INSTALL TO THIS DRAWING.

PLEASE DO NOT SCALE FROM THIS DRAWING.







## **District Heating Section 1**

C3 SJL AE 19/10/23 District Heating route amended to avoid Bin C2 SJL AE 26/06/23 Containment Route amended to avoid corridor door Knauf fixings as per meeting 22.06.23 C1 SJL AE 11/04/23 Construction Issue

db

T2 JE AE 20/09/22 Updated to latest ER's recieved & comments from design team
T1 SJL AE 15/06/22 T1 Issue P01 JE AE 25/04/22 Preliminary Issue

CLIENT

**LONDON SQUARE** HEAD OFFICE,

ONE YORK ROAD, UXBRIDGE, WWW.LONDONSQUARE.CO.UK

Designbrook Ltd, Unit J2, The Granary, Bridge Farm, Reading Road, Arborfield, Berkshire, RG2 9HT Tel: 0118 9 773 011

E-mail:admin@designbrook.co.uk PROJECT TITLE

The Hyde, Colindale, Phase 1 DRAWINGISSUE

Construction Issue DRAWING TITLE

Block B/C- Ground floor, Communal Heating Primary Service Routes

DRAWN JE 1:100@A1 CHECKED 23/06/2022 AJE DBR Project No. J6432 Identification Sheet Number

Drawing Number

6432-M-BC-00-100-56-110

This may be a reduced size print. Check scale in titleblock.