



Certificate of Analysis

Certificate Number 24-05009

Issued: 13-Mar-24

Client Earth Science Partnership
33 Cardiff Road
Taffs Well
Cardiff
CF15 7RB

Our Reference 24-05009

Client Reference ~ 8711

Order No ~ db/8711/12376.

Contract Title ~ CLIVE ROAD

Description One Misc sample.

Date Received 08-Mar-24

Date Started 08-Mar-24

Date Completed 13-Mar-24

Test Procedures Identified by prefix DETSn (details on request).

Notes Opinions and interpretations are outside the laboratory's scope of ISO 17025 accreditation. This certificate is issued in accordance with the accreditation requirements of the United Kingdom Accreditation Service. The results reported herein relate only to the material supplied to the laboratory. This certificate shall not be reproduced except in full, without the prior written approval of the laboratory.

Approved By



Kirk Bridgewood
General Manager



Normec DETS Limited

Unit 2, Park Road Industrial Estate South, Consett, Co Durham, DH8 5PY

Tel: 01207 582333 • email: info@dets.co.uk • www.dets.co.uk

Page 1 of 3

Summary of Asbestos Analysis

Bulk Samples

Our Ref ~ 24-05009

Client Ref ~ 8711

Contract Title ~ CLIVE ROAD

Lab No	Sample ID	Sample Location	Material Type*	Result	Comment*	Analyst
2309710	CLIVE ROAD		Cement	Chrysotile	none	D Wilkinson

Crocidolite = Blue Asbestos, Amosite = Brown Asbestos, Chrysotile = White Asbestos. Anthophyllite, Actinolite and Tremolite are other forms of Asbestos. Samples are analysed by DETSC 1101 using polarised light microscopy in accordance with HSG248 and documented in-house methods. NAD = No Asbestos Detected. Where a sample is NAD, the result is based on analysis of at least 2 sub-samples and should be taken to mean 'no asbestos detected in sample'. Key: * -not included in laboratory scope of accreditation.

Information in Support of the Analytical Results

Our Ref 24-05009
 Client Ref ~ 8711
 Contract ~ CLIVE ROAD

Containers Received & Deviating Samples

Lab No	Sample ID ~	Date Sampled ~	Containers Received	Hold time exceeded for tests	Inappropriate container for tests
2309710	CLIVE ROAD MISC	14/02/24	PT 1L		

Key: P-Plastic T-Tub
 DETS cannot be held responsible for the integrity of samples received whereby the laboratory did not undertake the sampling. In this instance samples received may be deviating. Deviating Sample criteria are based on British and International standards and laboratory trials in conjunction with the UKAS note 'Guidance on Deviating Samples'. All samples received are listed above. However, those samples that have additional comments in relation to hold time, inappropriate containers etc are deviating due to the reasons stated. This means that the analysis is accredited where applicable, but results may be compromised due to sample deviations. If no sampled date (soils) or date+time (waters) has been supplied then samples are deviating. However, if you are able to supply a sampled date (and time for waters) this will prevent samples being reported as deviating where specific hold times are not exceeded and where the container supplied is suitable.

Disposal

From the issue date of this test certificate, samples will be held for the following times prior to disposal :-
 Soils - 1 month, Liquids - 2 weeks, Asbestos (test portion) - 6 months

End of Report